

DECLARATION OF CONFORMITY



Manufacturer: **Sta.Ge HELLAS S.A.**

Product: **Lift Controller for Electric Elevators**

Type: **EL.CO Micro**

The present document certifies the product above conforms to the 95/16/EC (for Lifts).
 Device is tested at the laboratories of EMC HELLAS (December 2013)

In compliance with supplement V of order 95/16/EC the present document allows the company to apply the "CE".

LAB	TEST	STANDARDS APPLIED	RESULT
EMC HELLAS	CONDUCTED EMISSIONS	EN 12015:2004	PASS
EMC HELLAS	HARMONICS	EN 61000-3-2	PASS
EMC HELLAS	RF EMISSIONS	EN 12015:2004	PASS
EMC HELLAS	ESD IMMUNITY	EN 61000-4-2:2009	PASS
EMC HELLAS	RF EM FIELD	EN 61000-4-3:2006 +A1 +A2	PASS
EMC HELLAS	SURGE	EN 61000-4-4:2004 +A1	PASS
EMC HELLAS	EFT	EN 61000-4-5:2006	PASS
EMC HELLAS	RF CONDUCTED IMMUNITY	EN 61000-4-6:2009	PASS
EMC HELLAS	VOLTAGE DIPS & INT/PTIONS	EN 61000-4-11:2004	PASS
EMC HELLAS	CLICKS	EN 55014-1:2006 +A1:2009 +A2:2011	PASS
EMC HELLAS	Safety rules for the construction and installation of lifts - Part 1: Electric lifts	EN 81-1:1998+A3:2009§13.1.3	PASS
EMC HELLAS	Low-voltage switchgear and controlgear assemblies - Part 1: Type-tested and partially type-tested assemblies	EN 60439-1:2009 +A1:2004 §10.9.2. §10.5.2	PASS

Zaxaropoulos Paraskevas

Lab Supervisor
 EMC HELLAS S.A.

Ing. Panteleos Panagiotis

Technical Support Manager
 EMC HELLAS S.A.

For **Sta.Ge HELLAS S.A.**

GEORGE STAVGIANOUDAKIS

President