



DECLARATION OF CONFORMITY

Manufacturer: **Sta.Ge HELLAS S.A.**

Product: **Lift Controller for Hydraulic Elevators**

Type: **EL.CO Micro**

The present document certifies the product above conforms to the 95/16/EC (for Lifts).
Device is tested at the laboratories of EMC HELLAS (December 2013)

The Sta.Ge HELLAS S.A. company declares, under its only responsibility, that the product

EL.CO Micro HYDRAULIC

has been manufactured according to the requirements set below by the 89/336/ECC directive referring to the Electromagnetic Conditions (EMC) and for which it carries the CE mark.*

**In compliance with supplement V of order 95/16/EC*

LAB	TEST	STANDARDS APPLIED	RESULT
EMC HELLAS	CONDUCTED EMISSIONS	EN 12015:2004	PASS
EMC HELLAS	HARMONICS	EN 61000-3-2	PASS
EMC HELLAS	RF EMISSIONS	EN 12015:2004	PASS
EMC HELLAS	ESD IMMUNITY	EN 61000-4-2:2009	PASS
EMC HELLAS	RF EM FIELD	EN 61000-4-3:2006 +A1 +A2	PASS
EMC HELLAS	SURGE	EN 61000-4-4:2004 +A1	PASS
EMC HELLAS	EFT	EN 61000-4-5:2006	PASS
EMC HELLAS	RF CONDUCTED IMMUNITY	EN 61000-4-6:2009	PASS
EMC HELLAS	VOLTAGE DIPS & INT/PTIONS	EN 61000-4-11:2004	PASS
EMC HELLAS	CLICKS	EN 55014-1:2006 +A1:2009 +A2:2011	PASS
EMC HELLAS	Safety rules for the construction and installation of lifts - Part 2: Hydraulic lifts	EN 81-2:1998+A3:2009 §13.1	PASS
EMC HELLAS	Low-voltage switchgear and controlgear assemblies - Part 1: Type-tested and partially type-tested assemblies	EN 60439-1:2009 +A1:2004 §10.9.2. §10.5.2	PASS

Zaxaropoulos Paraskevas

Lab Supervisor
EMC HELLAS S.A.

Ing. Panteleos Panagiotis

Technical Support Manager
EMC HELLAS S.A.

For **Sta.Ge HELLAS S.A.**

GEORGE STAVGIANOUDAKIS

President